

**Testing & Certification**

Kahlenberger Str. 2A  
1190 Wien, Austria  
Phone: +43 1 370 58 06  
Fax: +43 1 370 58 06-199



# ÖVE-CERTIFICATE PHOTOVOLTAICS

including the entitlement to use the Austrian Safety Mark



Certificate No.: **49368-002**

Date of issue: Wien, 2012 04 04  
Rev. No. 02 Wien, 2013 03 08

The Austrian Electrotechnical Association (ÖVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Licenceholder: **Bisol Proizvodnja, d.o.o.**

Latkova vas 59a  
3312 Prebold  
Slovenia

Product: **Photovoltaic (PV) modules**

Basis for this given right is the conformity of the products with the requirements of the technical standards listed in this certificate as stated in the file(s) Ref.-No(s) **2.03.02261.1.0j, 2.03.02261.1.0k, 2.03.02261.1.0L.**

This certificate establishes the conformity of the tested specimen and of all products manufactured strictly identical to the submitted one. To ensure the continuous conformity of the product, factory inspections are performed periodically.

The product satisfies the provisions of the Low Voltage Directive 2006/95/EC.

Österreichischer Verband für Elektrotechnik


Digitally signed by W. Martin  
Email=w.martin@ove.at



**ÖVE – Testing & Certification**

Accredited by the Austrian Ministry of Economy, Family and Youth as Certification Body for products and processes in the field of electrical and electronic engineering, including safety and EMC



<p><i>Hersteller</i> <i>Manufacturer</i></p>	<p><b>Bisol Proizvodnja, d.o.o.</b> <b>Latkova vas 59a</b> <b>3312 Prebold</b> <b>Slovenia</b></p>
<p><i>Fertigungsstätte(n)</i> <i>Factory location(s)</i></p>	<p><b>Bisol Proizvodnja, d.o.o.</b> <b>Latkova vas 59a</b> <b>3312 Prebold</b> <b>Slovenia</b></p>
<p><i>Erzeugnis</i> <i>Product</i></p>	<p><b>Photovoltaic (PV) modules</b></p>
<p>* <i>Typenbezeichnung</i> <i>Type reference</i></p>	<p><b>BLO-240, BLO-245, BLO-250, BLO-251, BLO-255, BLO-257, BLO-260, BLO-263, BLO-265, BLO-269, BLO-270 BLU-225, BLU-227, BLU-230, BLU-233, BLU-235, BLU-239, BLU-240, BLU-245, BLU-250, BLU-251, BLU-255</b></p>
<p><i>Warenzeichen</i> <i>Trade Mark</i></p>	
<p><i>Prüfbericht</i> <i>Test Report</i></p>	<p><b>2.03.02261.1.0j, 2.03.02261.1.0k, 2.03.02261.1.0L</b></p>
<p><i>Nationale Bestimmung(en)</i> <i>National Standard(s)</i></p>	<p><b>ÖVE/ÖNORM EN 61730-1:2007-12-01 ÖVE/ÖNORM EN 61730-2:2007-12-01 ÖVE/ÖNORM EN 61215:2006-04-01</b></p>
<p><i>Europannorm(en)</i> <i>European Standard(s)</i></p>	<p><b>EN 61730-1:2007 EN 61730-2:2007 EN 61215:2005</b></p>
<p><i>IEC Publikation(en)<sup>1</sup></i> <i>IEC Publication(s)<sup>1</sup></i></p>	<p><b>IEC 61730-1:2004 IEC 61730-2:2004 IEC 61215:2005</b></p>
<p>* <i>Ersatz für Zertifikat</i> <i>Superseded licence</i></p>	<p><b>49368-002 Rev. 01 dated 2012 08 01</b> <b>Items modified are marked with an asterisk (*)</b></p>
<p><i>Anmerkung(en)</i> <i>Remark(s)</i></p>	<p><sup>1</sup> The fire test (IEC 61730-2 / MST 23) had not been carried out.</p>